Summary concerning fire classification of wood products

Metsä Wood Spruce FireResist Kerto FireResist Metsä Wood Birch Phoenix Metsä Wood Spruce Phoneix

Requested by: Metsä Wood





Requested by

Metsä Wood

P.O.Box 24

FI-08101 Lohja, Finland

Order

22 March 2016 / Anu Huovinen

Contact person at VTT VTT Expert Services LTD

Product Manager Tiia Ryynänen

Kivimiehentie 4, Espoo, P.O. Box 1001, FI-02044 VTT, Finland

Tel. + 358 20 722 4827, Email: tiia.ryynänen@vtt.fi

Assignment

Summary concerning fire classification of wood products

Products

Metsä Wood Spruce FireResist

Kerto FireResist

Metsä Wood Birch Phoenix Metsä Wood Spruce Phoenix

According to the customer both surfaces of the products are similar.

The products are described in the classification reports mentioned below.

Classification reports

Summary is based on the following classification reports:

Metsä Wood Spruce FireResist and Kerto FireResist:

Classification report No. VTT-S-3338-11 dated 10 May 2011 Classification report No. VTT-S-00781-16 dated 11 March 2016

Metsä Wood Spruce FireResist and Kerto FireResist as floorings: Classification report No. VTT-S-2-12 dated 17 January 2012

Metsä Wood Birch Phoenix:

Classification report No. VTT-S-2510-12 dated 29 March 2012

Metsä Wood Spruce Phoenix:

Classification report No. VTT-S-2511-12 dated 29 March 2012

The test results relate only to the sample tested.



Classes of the products and validity of classification

The reaction to fire classification of **Metsä Wood Spruce FireResist** and **Kerto FireResist** is B-s1,d0. This classification is valid for the following product parameters and end use conditions:

- thickness of the products $\geq 15 \text{ mm}$
- without joints or with closed vertical and horizontal joints
- fixed mechanically to wooden or metallic frames
- without an air gap between the products and a substrate of class A1 or A2-s1,d0 with a density of at least 30 kg/m³

The reaction to fire classification of **Metsä Wood Spruce FireResist** and **Kerto FireResist** is B-s2,d0. This classification is valid for the following product parameters and end use conditions:

- thickness of the products ≥ 15 mm
- without joints or with closed vertical and horizontal joints
- fixed mechanically to wooden or metallic frames
- with or without an air gap between the products and a substrate of class A1 or A2-s1,d0 and density of at least 540 kg/m³

The reaction to fire classification of **Metsä Wood Spruce FireResist** and **Kerto FireResist** as floorings is B_{fl} -s1. This classification is valid for the following product parameters and end use conditions:

- thickness of the products $\geq 12 \text{ mm}$
- with or without an air gap between the products and a wood based substrate or any substrate of class A1 or A2-s1,d0 with density of at least 470 kg/m³; the air gap can be filled with a thermal insulation of class A1 or A2-s1,d0 with density at least 23 kg/m³
- without an air gap between the products and a plywood substrate with a density of at least 400 kg/m³

The test results relate only to the sample tested.



The reaction to fire classification of **Metsä Wood Birch Phoenix** is B-s1,d0. This classification is valid for the following product parameters and end use conditions:

- thickness of the product $\geq 12 \text{ mm}$
- without joints or with vertical and horizontal 2 mm butt joints
- fixed mechanically to wooden or metallic frames
- the substrate is of class A1 or A2-s1,d0 and density of at least 30 kg/m³

The reaction to fire classification of **Metsä Wood Spruce Phoenix** is B-s1,d0. This classification is valid for the following product parameters and end use conditions:

- thickness of the product $\geq 12 \text{ mm}$
- without joints or with vertical and horizontal ≤ 8 mm open joints
- fixed mechanically to wooden or metallic frames
- the substrate is of class A1 or A2-s1,d0 and density of at least 30 kg/m³

Espoo, 20 April 2016

Kai Renholm

Business Manager

Tiia Ryynänen

Product Manager

DISTRIBUTION

Customer Archive Original (2) Original

The test results relate only to the sample tested.